

Customer <u>Lower Makefield Twpshp.</u>		Ship to <u>Community Center</u>	
Address <u>1100 Edgewood Rd.</u>		Address <u>1550 Oxford Valley Rd.</u>	
City, State, Zip <u>Yardley, PA 19067</u>	Phone	City, State, Zip <u>Yardley, PA 19067</u>	Contact <u>Lynn</u> Cell <u>267-274-1103</u>
Fuel Source: <input checked="" type="checkbox"/> Gas <input type="checkbox"/> Electric	Gas Valve Type <u>Mechanical</u> Elec. <input type="checkbox"/> N/A	Number of Nozzles Duct <u>1</u> Plenum <u>1</u> Appliance <u>2</u>	Hydro Test Date Month <u>1</u> Year <u>2017</u>
<input type="checkbox"/> Initial <input type="checkbox"/> Recharge <input checked="" type="checkbox"/> Semi-Annual <input type="checkbox"/> Retrofit <input type="checkbox"/> Annual		Mfg <u>Ansul</u>	Model <u>R-102</u>
		Size <u>36</u>	Type <u>watchman</u>
		No of Cyl. <u>1</u>	

The term of this agreement shall be one (1) year from the date hereof and shall be automatically renewed each year thereafter until the same shall be terminated by either party with at least thirty (30) days written notice being given to the other party prior to the anniversary date thereof. Contractor's then current charges shall apply for the renewal period. Customers Initials

Pre-Inspection	Operations Test
1. Has hazard changed since last service? <input checked="" type="radio"/> yes <input checked="" type="radio"/> no <input type="radio"/> n/a	19. Systems disarmed prior to operations test?..... <input checked="" type="radio"/> yes <input checked="" type="radio"/> no <input type="radio"/> n/a
2. Has system been discharged or tampered with? <input checked="" type="radio"/> yes <input checked="" type="radio"/> no <input type="radio"/> n/a	20. Proper Ansul bursting disc(s) in place? <input checked="" type="radio"/> yes <input checked="" type="radio"/> no <input type="radio"/> n/a
3. System cylinder(s) with hydrotest date? <u>2017</u> <input checked="" type="radio"/> yes <input checked="" type="radio"/> no <input type="radio"/> n/a	(A) Did the release mechanism trip? <input checked="" type="radio"/> yes <input checked="" type="radio"/> no <input type="radio"/> n/a
4. Ansul regulator within regulator test date? <input checked="" type="radio"/> yes <input checked="" type="radio"/> no <input type="radio"/> n/a	(B) Did gas valve close? <input checked="" type="radio"/> yes <input checked="" type="radio"/> no <input type="radio"/> n/a
5. Cylinder exterior in acceptable condition?..... <input checked="" type="radio"/> yes <input checked="" type="radio"/> no <input type="radio"/> n/a	(C) Did micro switch/pressure switch trip? <input checked="" type="radio"/> yes <input checked="" type="radio"/> no <input type="radio"/> n/a
6. Pressure gauge within operable range? <input checked="" type="radio"/> yes <input checked="" type="radio"/> no <input type="radio"/> n/a	(D) Did protected appliances shut down properly?.. <input checked="" type="radio"/> yes <input checked="" type="radio"/> no <input type="radio"/> n/a
7. Distribution piping correct and secured? <input checked="" type="radio"/> yes <input checked="" type="radio"/> no <input type="radio"/> n/a	(E) Did required electrical sources shut down?..... <input checked="" type="radio"/> yes <input checked="" type="radio"/> no <input type="radio"/> n/a
8. All conduit intact and free of excessive grease? <input checked="" type="radio"/> yes <input checked="" type="radio"/> no <input type="radio"/> n/a	21. Manual pull tripped and functioning properly?..... <input checked="" type="radio"/> yes <input checked="" type="radio"/> no <input type="radio"/> n/a
9. All appliances properly protected & under hood? ... <input checked="" type="radio"/> yes <input checked="" type="radio"/> no <input type="radio"/> n/a	22. All cables & pulleys in acceptable condition?..... <input checked="" type="radio"/> yes <input checked="" type="radio"/> no <input type="radio"/> n/a
10. All nozzles are proper and correctly positioned? ... <input checked="" type="radio"/> yes <input checked="" type="radio"/> no <input type="radio"/> n/a	23. Alarms and auxiliary equipment working properly?... <input checked="" type="radio"/> yes <input checked="" type="radio"/> no <input type="radio"/> n/a
11. Pipe and nozzles inspected for obstructions? <input checked="" type="radio"/> yes <input checked="" type="radio"/> no <input type="radio"/> n/a	24. Fusible links replaced? <input checked="" type="radio"/> yes <input checked="" type="radio"/> no <input type="radio"/> n/a
12. Proper detection in place and secure? <input checked="" type="radio"/> yes <input checked="" type="radio"/> no <input type="radio"/> n/a	1 _____ quantity <u>360°</u> temperature
13. Hood penetrations welded or sealed? <input checked="" type="radio"/> yes <input checked="" type="radio"/> no <input type="radio"/> n/a	2 _____ quantity _____ temperature
14. Manual pull properly located and unobstructed?.. <input checked="" type="radio"/> yes <input checked="" type="radio"/> no <input type="radio"/> n/a	Post Operations Test
15. Ansul activation cartridge replaced _____ oz. <input checked="" type="radio"/> yes <input checked="" type="radio"/> no <input type="radio"/> n/a	25. All cables checked for proper adjustments?..... <input checked="" type="radio"/> yes <input checked="" type="radio"/> no <input type="radio"/> n/a
_____ oz. <input checked="" type="radio"/> yes <input checked="" type="radio"/> no <input type="radio"/> n/a	26. All gas appliances relit and electric on?..... <input checked="" type="radio"/> yes <input checked="" type="radio"/> no <input type="radio"/> n/a
16. CO-2 activation cartridge replaced? <input checked="" type="radio"/> yes <input checked="" type="radio"/> no <input type="radio"/> n/a	27. Tank connections/hoses properly connected?..... <input checked="" type="radio"/> yes <input checked="" type="radio"/> no <input type="radio"/> n/a
17. Internal inspection for stoppage checked <input checked="" type="radio"/> yes <input checked="" type="radio"/> no <input type="radio"/> n/a	28. Were all nozzle caps replaced at time of service?..... <input checked="" type="radio"/> yes <input checked="" type="radio"/> no <input type="radio"/> n/a
18. Annually, purge system piping <u>2022</u> last date <input checked="" type="radio"/> yes <input checked="" type="radio"/> no <input type="radio"/> n/a	29. System armed and returned to service? <input checked="" type="radio"/> yes <input checked="" type="radio"/> no <input type="radio"/> n/a

<input checked="" type="checkbox"/> System is Compliant	Hood & Filters free of excessive grease? <input checked="" type="radio"/> yes <input checked="" type="radio"/> no <input type="radio"/> n/a
<input type="checkbox"/> System is Non-Compliant	Proper fire extinguishers and signage located in hazard areas? <input checked="" type="radio"/> yes <input checked="" type="radio"/> no <input type="radio"/> n/a
System meets UL300 Standards? <input checked="" type="radio"/> yes <input checked="" type="radio"/> no <input type="radio"/> n/a	

Comments _____

Notification of Deficiencies:

A mark made in the adjacent box indicates that deficiencies exist in the current condition of your fire suppression system. If this is the case, the customer authorized representative, by his or her signature and initials acknowledges these deficiencies represent an immediate and serious safety concern that the customer must correct. J.W. Kennedy, LLC. shall and will not be responsible if the fire suppression system malfunctions or fails to function. By code it is the owner's responsibility to insure that all deficiencies/impairments are removed or repaired. _____ customer's initials

Certificate of Inspection
NOT VALID UNLESS COMPLETED AND SIGNED

This certifies that the above equipment was inspected and left in operating condition with N.F.P. A. and original manufacturer's prescribed procedures. However, any comments or deficiencies noted must be addressed as soon as possible for total fire protection.

X [Signature] _____
Signature of Customer's Authorized Representative Date 1, 26, 23

[Signature] _____
J. W. Kennedy, LLC Service Technician Date 1, 26, 23

Phone: 609-989-7700
 Fax: 1-609-989-7410
 Web: www.jwkennedyllc.com



JOB / WORK ORDER
 NJ DFS #P00001

FIRE PROTECTION PROFESSIONALS
 536 PERRY STREET TRENTON, NJ 08618-3943

SOLD TO: LOWER MAKEFIELD TOWNSHIP
 ATTN: ACCTS PAYABLE
 1100 EDGEWOOD RD
 YARDLEY, PA 19067

APPOINTMENT
REQUIRED

SHIP TO: COMMUNITY CENTER
 1550 OXFORD VALLEY RD
 YARDLEY, PA 19067

DATE: 1/26/25

Purchase Order: _____

CONTACT: Lynn

EXT: _____

PHONE NUMBER	SOLD BY	CASH	C.O.D.	CHARGE	PICK-UP	DELIVERED	SERVICE TECH	SHIPMENT PART	SHIPMENT COMP
267.274.1103							Tom		

INSPECTION INTERVAL: INITIAL ANNUAL SEMI-ANNUAL QUARTERLY MONTHLY
 JAN. FEB. MAR. APR. MAY. JUN. JUL. AUG. SEP. OCT. NOV. DEC.

The term of this agreement shall be (1) year from the date hereof and shall be automatically renewed each year thereafter until the same shall be terminated by either party on at least (30) days written notice being given to the other party prior to the anniversary date thereof. Contractor's then current charges shall apply for the renewal period.

FIRE EXT. SERVICE CODES	QUAN.	CODE	SIZE	ANNL INSP.	RCHG	6 YR. MAINT	HYDRO TEST	PRICE	AMOUNT
1. ABC Dry Chem. 7. Air Pak									
2. Std. Dry Chem 8. Cartridge									
3. Purple-K Dry Chem. 9. Oxygen									
4. Carbon Dioxide 10. Nitrogen									
5. Clean Agent 11. Foam AFFF									
6. Pressurized Water 12. Other (specify)									
TIME IN									
TIME OUT									
MILEAGE									
TRAVEL									

SECOND TRIP ON INSPECTION CHARGE

YOUR ATTENTION PLEASE: Our Service Technician has been instructed to request confirmation as to the total units to be service at your location. Should additional units be found after the annual inspection is performed. It will automatically constitute an additional fee. I have been fully advised and understand this policy.

QUANTITY	PART NUMBER	DESCRIPTION	PRICE	AMOUNT
1		Semi-Annual Inspection Ansul 36		
1	ML360	360° Link		
1		Fuel Surcharge		

COMMENTS: _____

	SUB-TOTAL	
	TAX	
	FREIGHT	
	LABOR	
	TOTAL	

TERMS: Net 30 days for customers with approved credit. Finance charge is computed by a periodic rate of 1.5% per month, which is an annual percentage rate of 18% applied to the balance due after deducting current payments and/or credits. Should it become necessary to refer any balance owing to an outside source for collection, customer agrees to pay all collection costs plus reasonable attorney's fees. No other express warranty is given by Company. All implied warranties, including implied warranties of merchantability or fitness for a particular purpose are limited in duration to a time equal to the period of the express warranty as herein-above set forth. Company shall not be liable for consequential damages. Except as expressly set forth herein. Customer has relied on no representations or warranties made by the Company and Customer assumes all risk for loss or damages to his premises or contents. In the event Customer shall resell any of the equipment herein provided, then and in that event, this warranty shall be void and of no further force and effect.

REC'D BY *Lynn Todd*